

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 4207.....

Dated: 26...../07...../2024

It is Certified that an inspection team headed by Dr. Tulesh Bansal
Medical officers.....(Name of Officers with designation)
from 25/07/2024.....(Name
of Department/Office) inspected the Bachpan International Public School Mandvi
Road, VPO. Hamirgarh Teh. Moonak, Distt. Sangrur(Name & Address of the
School) on 25/07/2024..... (date of inspection), checked the water test report
submitted by the school and found that the school has potable drinking water for
students and staff of the institution and is having provision for running water in the
toilets and maintaining hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of One year

Signature with Seal: TMB
ਮੈਡੀਕਲ ਅਫਸਰ
ਪੀ. ਐਚ. ਐਚ. ਸੀ., ਮੁਨਾਕ

Name : TULESH BANISAL

Designation: MEDICAL OFFICER

To

Bachpan International Public School
Mandvi Road, VPO. Hamirgarh
Teh. Moonak, Distt. Sangrur
(Name & Address of the Institution)

REGIONAL WATER TESTING LAB, SANGRUR
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtsangrur@gmail.com



TEST REPORT			
Name & Address of Customer : BACHPAN INTERNATIONAL PUBLIC SCHOOL VILL-HAMIRGARH,MOONAK		Customer Reference No.	No : BIPS/113/24 Dated : 21/06/2024
		Sample Submitted by	
		Date of Sample Receipt	19/06/2024
		Analysis Starting Date	19/06/2024
		Analysis completion Date	25/06/2024
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC129902400000134F	Sample Type :	Treated Water
Test Report No.:	RWTL/SNG/2425/00646	Date of Issue :	05/07/2024
Registration no.:	RWTL/SNG/REG2425/00344	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Anndana	District :	Sangrur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.86	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	147	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity(CaCO3)	60	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness(CaCO3)	88	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
8	Calcium(Ca)	18	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium(Mg)	11	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	30	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Sangrur

----- End of the Test Report -----